

Confirmation

BREEAM[®] UK and BREEAM[®] Int.

On 31 January 2020, Eurofins Product Testing A/S received a sample of paint with the product name:

Armstead Trade Durable Matt White

supplied by

AkzoNobel Decorative Paints

The sample was supplied as being representative of the manufactured product, and it has been tested as in accordance with the relevant EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 and ISO 11890-2 testing standards (See test report no. 392-2020-00056624_A_EN and 392-2020-00056609_XG_EN).

Evaluation of the emission and content test results according to the basic level emission criteria and VOC content criteria of BREEAM[®] Int. and BREEAM[®] UK:

- Carcinogenic substances were not detectable after 28 days (< 0.001 mg/m³).
- The sum of VOC ("TVOC") after 28 days was below the limit of 1.0 mg/m³.
- Formaldehyde after 28 days was below the limit of 0.06 mg/m³.
- VOC content of less than 10 g/L.

The tested product complies with the requirements of:

BREEAM[®] UK: New Construction 2018, Technical Manual: Hea 02 Indoor air quality (version SD5078 issue 3.0 of July 2019)

and

BREEAM[®] International: BREEAM International: New Construction 2016, Technical Manual: Hea 02 Indoor Air Quality (version SD233 issue 2.0 of July 2017).

2 November 2020



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry