

# Attestation

## BREEAM<sup>®</sup> UK and BREEAM<sup>®</sup> Int.

On 25 November 2019 and 24 February 2020, Eurofins Product Testing A/S received samples of paints with the product name:

### DULUX TRADE EVOLVE MATT WHITE

supplied by

### AkzoNobel Decorative Paints

The samples were supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the relevant EN 16516, ISO 16000, CDPH 01350 and ISO 11890-2 testing standards (See test report no. 392-2019-00495901\_H\_EN and no. 392-2020-00092110\_XG\_EN).

#### **Evaluation of the emission and content test results according to the basic level emission criteria and VOC content criteria of BREEAM<sup>®</sup> Int. and BREEAM<sup>®</sup> UK:**

- Carcinogenic substances were not detectable after 14 days (< 0.001 mg/m<sup>3</sup>).
- The sum of VOC ("TVOC") after 14 days was below the limit of 1.0 mg/m<sup>3</sup> in the class room scenario.
- Formaldehyde after 14 days was below the limit of 0.01 mg/m<sup>3</sup>.
- VOC content of less than 10 g/L.


**The tested product complies with the requirements of:**

**BREEAM<sup>®</sup> UK: New Construction 2018, Technical Manual: Hea 02 Indoor air quality (version SD5078 issue 3.0 of July 2019)**

**and**

**BREEAM<sup>®</sup> International: BREEAM International: New Construction 2016, Technical Manual: Hea 02 Indoor Air Quality (version SD233 issue 2.0 of July 2017).**

2 November 2020



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry