

# Confirmation

## LEED v4.1

On 31 January 2020, Eurofins Product Testing A/S received a sample of a paint with the product name:

### **Dulux Trade Mouldshield Fungicidal Eggshell PBW**

supplied by

### **AkzoNobel Decorative Paints**

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 11890-2 and CDPH 01350 testing standards (See test report no. 392-2020-00056623\_H\_EN and no. 392-2020-00056603\_XG\_EN).

**The test results of the tested sample indicate that the product qualifies for LEED v4.1 BETA (July 2019) specifications on VOC emissions and VOC content by complying with:**

**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- the requirements of CDPH-IAQ (California Department of Public Health (CDPH) Standard Method v1.2-2017 (worst case relative to v1.0-2010)); and a TVOC between 0.5 – 5 mg/m<sup>3</sup> in both classroom and office scenario.

**VOC content specifications in LEED EQ credit "Low-emitting products":**

- the requirements of the EU Decopaint Directive 2004/42/EC

17 April 2020



Malene Laugesen  
Analytical Service Manager



Janne Rothmann Norup  
Analytical Service Manager

*LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.*