

Confirmation

LEED v4.1

On 31 January 2020, Eurofins Product Testing A/S received a sample of a paint with the product name:

Dulux Trade Sterishield Matt PBW

supplied by

AkzoNobel Decorative Paints

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 11890-2 and CDPH 01350 testing standards (See test report no. 392-2020-00056625_H_EN and no. 392-2020-00056610_XG_EN).

The test results of the tested sample indicate that the product qualifies for LEED v4.1 BETA (July 2019) specifications on VOC emissions and VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of CDPH-IAQ (California Department of Public Health (CDPH) Standard Method v1.2-2017 (worst case relative to v1.0-2010)); and a TVOC between 0.5 – 5 mg/m³ in both classroom and office scenario.

VOC content specifications in LEED EQ credit "Low-emitting products":

- the requirements of the EU Decopaint Directive 2004/42/EC

17 April 2020



Janne Rothmann Norup
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.