

# Confirmation

## BREEAM<sup>®</sup>

On 20 May 2020, Eurofins Product Testing A/S received a sample of paint with the product name:

### Sikkens Alphatex SF Base N00

supplied by

### AkzoNobel Decorative Paints

The sample was supplied as being representative of the manufactured product, and it has been tested as in accordance with the relevant EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 and ISO 11890-2 testing standards (See test report no. 392-2020-00216704\_A\_EN and 392-2020-00216715\_XG\_EN).

The test results of the tested sample indicate that the product qualifies for the below mentioned BREEAM specifications on VOC emissions and VOC content by complying with:

- **BREEAM<sup>®</sup> UK: Compliance with Exemplary criteria on both VOC emission and VOC content** of BREEAM UK: New Construction 2018, Technical Manual: Hea 02 Indoor Air Quality (version SD5078 issue 3.0 of July 2019)
- **BREEAM<sup>®</sup> International: Compliance with Exemplary criteria on both VOC emission and VOC content** of BREEAM International: New Construction 2016, Technical Manual: Hea 02 Indoor Air Quality (version SD233 issue 2.0 of July 2017)
- **BREEAM<sup>®</sup>NOR: Compliance with criteria on both VOC emission and VOC content** of BREEAM-NOR 2016 New Construction, Technical Manual SD5075NOR, Hea 02 Indoor Air Quality (version 1.2 of June 2019)

2 November 2020



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry